



1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205
Fax: (888) 818-2978
Email: lab@exactscientific.com

Water Chemical Analysis

174 32166

Sample: Finished Sample Tap
Client: Glacier Springs Water System
PO Box 126
Maple Falls, WA 98226
Phone: (360) 739-3933
Email: john@watersystems-services.net

Invoice Number: 25-09299

P.O. Number:

Report Date: 6/3/2025

Approved By:

PWS Information

Date Collected:	6/2/2025	Sample Collected by:	Isaac Colgan
Sample Purpose:	Routine Compliance	System Group Type:	A
Sample Type:	Post Treatment/Finished Water Sample	County:	WHATCOM
Sample Composition:	Samples from a single source	Source Number:	1
Sample Collection:	Flowing	Date Received:	6/2/2025
Suitability:	Yes	Date Analyzed:	6/2/2025
		Date Approved:	6/3/2025

System Number: 27755

System Name: GLACIER SPRINGS WATER SYSTEM

Lab #: 32166		Sample: Finished Sample Tap						
DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
EPA Regulated								
20	NITRATE-N	ND	mg/L	0.5	5.0	10.0	300.0_NO3	KH

Definitions, Qualifiers and Notes:

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

SMCL = Secondary Maximum Contaminant Level from EPA - NSDWR

OT = Out of Hold Time

RR = Revised Result

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.