



1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205
Fax: (888) 818-2978

Email: lab@exactscientific.com

Water Chemical Analysis

174 45136

Sample: Reservoir In
Client: Glacier Springs Water System
PO Box 126
Maple Falls, WA 98226
Phone: (360) 739-3933
Email: john@watersystems-services.net

Invoice Number: 25-12804

P.O. Number:

Report Date: 7/22/2025

Approved By:

PWS Information

Date Collected: 7/21/2025

Sample Purpose: Investigative

Sample Type: Pretreatment/RawWater Sample

Sample Composition: Samples from a single source

Sample Collection: Flowing

Suitability: Yes

Sample Collected by:

System Group Type: A

County: WHATCOM

Source Number: 1

Date Received: 7/21/2025

Date Analyzed: 7/21/2025

Date Approved: 7/22/2025

System Number: 27755

System Name: GLACIER SPRINGS WATER SYSTEM

Lab #: 45136		Sample: Reservoir In						
DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
State Regulated								
17	TURBIDITY	1.0	NTU	0.1	---	---	SM_2130B	KH

Definitions, Qualifiers and Notes:

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

SMCL = Secondary Maximum Contaminant Level from EPA - NSDWR

OT = Out of Hold Time

RR = Revised Result

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.



1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205
Fax: (888) 818-2978
Email: lab@exactscientific.com

Water Chemical Analysis

174 45137

Sample: East Reservoir Out
Client: Glacier Springs Water System
PO Box 126
Maple Falls, WA 98226
Phone: (360) 739-3933
Email: john@watersystems-services.net

Invoice Number: 25-12804

P.O. Number:

Report Date: 7/22/2025

Approved By:

PWS Information

Date Collected: 7/21/2025

Sample Purpose: Investigative

Sample Type: Post Treatment/Finished Water Sample

Sample Composition: Samples from a single source

Sample Collection: Flowing

Suitability: Yes

Sample Collected by:

System Group Type: A

County: WHATCOM

Source Number: 1

Date Received: 7/21/2025

Date Analyzed: 7/21/2025

Date Approved: 7/22/2025

System Number: 27755

System Name: GLACIER SPRINGS WATER SYSTEM

Lab #: 45137		Sample: East Reservoir Out						
DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
State Regulated								
17	TURBIDITY	0.50	NTU	0.1	---	---	SM_2130B	KH

Definitions, Qualifiers and Notes:

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

SMCL = Secondary Maximum Contaminant Level from EPA - NSDWR

OT = Out of Hold Time

RR = Revised Result

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.



1355 Pacific Place
Suite 101
Ferndale, WA 98248

Phone: (360) 733-1205
Fax: (888) 818-2978

Email: lab@exactscientific.com

Water Chemical Analysis

174 45138

Sample: West Reservoir Out
Client: Glacier Springs Water System
PO Box 126
Maple Falls, WA 98226
Phone: (360) 739-3933
Email: john@watersystems-services.net

Invoice Number: 25-12804

P.O. Number:

Report Date: 7/22/2025

Approved By:

PWS Information

Date Collected: 7/21/2025

Sample Purpose: Investigative

Sample Type: Post Treatment/Finished Water Sample

Sample Composition: Samples from a single source

Sample Collection: Flowing

Suitability: Yes

Sample Collected by:

System Group Type: A

County: WHATCOM

Source Number: 1

Date Received: 7/21/2025

Date Analyzed: 7/21/2025

Date Approved: 7/22/2025

System Number: 27755

System Name: GLACIER SPRINGS WATER SYSTEM

Lab #: 45138		Sample: West Reservoir Out						
DOH #	Analyte	Results	Units	SRL	Trigger	MCL	Method	Analyst
State Regulated								
17	TURBIDITY	0.35	NTU	0.1	---	---	SM_2130B	KH

Definitions, Qualifiers and Notes:

MCL = (Maximum Contaminant Level) allowed by the State of Washington.

SMCL = Secondary Maximum Contaminant Level from EPA - NSDWR

OT = Out of Hold Time

RR = Revised Result

ND = (Not Detected) Compound was analyzed and not detected at a level greater than or equal to the SRL.

SRL = (State Reporting Level) The minimum reporting level required by Washington State Department of Health (DOH).

Trigger Level = DOH drinking water response level. System with compounds detected at concentrations in excess of this level are required to take additional samples.

< = (less than) indicates the analyte was below the detection limit.